

## 2016 Annual Compliance Audit

Water System: RIVERCREST - PWS

Code: 179.00

Water System Owner: Rural Municipality of West St. Paul

Water System Operating Licence: PWS-11-486-01

Expiry Date: November 30, 2021

- 1) This report documents the Rivercrest Public Water System compliance for the period from January 1 to December 31, 2016.
- 2) Addendum A to this report provides specific information on the non-compliance incidents identified in the summary below.
- 3) Other than the information provided in attached Addendum A, the water supplier has complied with *The Drinking Water Safety Act*, its supporting regulations, and the terms and conditions of the water system's current operating licence
- 4) This report is based on information submitted by the water supplier, agents of the water supplier, and / or the Province of Manitoba.

### Summary of Non-Compliance Incidents:

- |                                                                                             |
|---------------------------------------------------------------------------------------------|
| <ul style="list-style-type: none"><li>• Failure to Meet Disinfection Requirements</li></ul> |
|---------------------------------------------------------------------------------------------|

**Sustainable Development**

Addendum A: Record of Non-Compliance  
Water System: RIVERCREST - PWS  
Report period: January 1, 2016 to December 31, 2016.

***Enforcement Action Taken***

Date	Clause	Incident	Outcome
		None reported	

***Disinfection Requirements***

Date	Samples	Incident	Outcome
April	1	Failure to maintain a free chlorine residual of at least 0.1 mg/L at all times at any point in the water distribution system	Non-compliant

***Bacteriological Requirements***

Date	Samples	Incident	Outcome
		None reported	

***Microbial Requirements***

Date	Clause	Incident	Outcome
		None reported	

***Turbidity Requirements***

Date	Samples	Incident	Outcome
		None reported	

***Chemical Requirements***

Date	Clause	Incident	Outcome
		None reported	

***Operational Requirements***

Date	Clause	Incident	Outcome
		None reported	