

Annual Lead Testing Results 2025

Test Month (2025)	ALS Reference	Address	Limit (MG/L)	Test Result
May	WP2506966-001	Pendennis Drive	0.005	0.00104
May	WP2506966-002	Norham Road	0.005	0.00112
May	WP2506966-003	Pendennis Drive	0.005	0.000961
June	WP2509753-001	Norham Road	0.005	0.00101
June	WP2509753-002	Allenford Drive	0.005	0.00104
June	WP2509753-003	Allenford Drive	0.005	0.000118
July	WP2511253-001	Dalemead Crescent	0.005	0.00128
July	WP2511253-002	Dalemead Crescent	0.005	0.00039
July	WP2511253-003	Allenford Drive	0.005	0.000538
July	WP2511866-001	Allenford Drive	0.005	0.000282
July	WP2511866-002	Norham Road	0.005	0.000156
July	WP2511866-003	Norham Road	0.005	0.000088
July	WP2512027-001	Allenford Drive	0.005	0.000193
July	WP2512027-002	Norham Road	0.005	0.000571
September	WP2515136-001	Allenford Drive	0.005	0.00165
October	WP2517152-001	Pendennis Drive	0.005	0.000051
October	WP2517152-002	Norham Road	0.005	0.00009
October	WP2517152-003	Dalemead Crescent	0.005	0.000051
November	WP2519975-001	Dalemead Crescent	0.005	0.000345
November	WP2519975-002	Norham Road	0.005	0.000395